


200 AMP UNDERGROUND METER POLE FOR MOBILE HOME

Note:

- Meter Base to be Spotted by Nolin RECC Personnel
- 42" Ditch Shall be Inspected by Nolin RECC Personnel Before Backfill
- Meter Base shall have a By-Pass Lever
- Schedule 80 PVC on all conduit above ground

Nolin RECC Pole

Detail Support Bolt



3' Minimum
4' Maximum

200 Amp Underground Meter Base

Pressure Treated 6" x 6"
Pressure Treated 2" x 6"

200 Amp Mobile Home Panel Box

200 AMP Dis-connect Panel

5' Minimum
6' Maximum
No.6 CU Continuous Ground Wire (City of E-town requires 12" of bare ground wire from the meter base and the rest enclosed in PVC to 3" below ground level)

6'6" Minimum

Pull Rope

Support Bolts

Approved Ground Clamps

12"

42" Min.

Final Grade

6' Min.

3' 6"

Refer to NEC Code or Contact Electrical Inspector for conduit size & depth

36" Radius Elbow

2 1/2" Electrical Schedule 40 PVC

← Minimum 8' x 1/2" Diameter Solid Copper Rod or a 5/8" Solid Galvanized Rd

City of Elizabethtown requires 10' min. between ground rod.

Nolin Rural Electric Cooperative Corp.
411 Ring Rd
Elizabethtown KY 42701
270-765-6153

Rev. 11/07
200 UG MH